

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.DPH/TPT/2025

Dated: 09.07.2025

It is certified that an inspection team headed by...

Sri P. Abdul Rahman..... Senior Water Analyst. (Name of Officers with designation) from

Dist Public Health Lab Tirupati i/c DPH Lab Kadapa PHED

Inspected the... EDIFY SCHOOL
BUGGILETI PALLI C.K DINNE (M) KADAPA 516003 YSR KADAPA DIST

(Name & Address of the school) on ...09.07.2025.....(date of inspection) and on the
basis of Water Test Report (Attached) bearing no...55/C/2025.....
dated...09.07.2025. of Dist Public Health Lab Tirupati (PHED Lab)

certified that the... EDIFY SCHOOL BUGGILETI PALLI C.K DINNE (M) KADAPA DIST
(Name of school) has safe drinking water facilities for the students and members of staff of the
institution. School is also maintains the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till.....31.07. 2026.....

Signature with Seal:
Name (P. Abdul Rahman)

Designation :..... SENIOR WATER ANALYST
Name & Address of the Office/ Department: DIST. PUBLIC HEALTH LABORATORY
TIRUPATI - 517 507

To
The
EDIFY SCHOOL BUGGILETI PALLI
C.K DINNE (M) KADAPA 516003
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies



DISTRICT PUBLIC HEALTH LABORATORY

6-1-3A OLD MATERNITY HOSPITAL ROAD TIRUPATHI
(Under the Control of the Directorate, I.P.M. P.H. Labs., AP)

REPORT OF CHEMICAL EXAMINATION OF WATER

Name & Address of Sender	EDIFY SCHOOL BUGGILETI PALLI C K DINNE (MANDAL) KADAPA 516 003 YSR DT						
Senders ref No.				Collected by	DPH STAFF KADAPA		
Date of Sample Collected	05 th	JULY	2025	Date of Receipt	05 th	JULY	2025
Lab Reference Number	55/DPH/C/2025			Receipt Number	CFMS 91111928162025		
Source of the Sample	R O Water* (sample tested as received basis)						

RESULTS A-PHYSICAL CHARACTERISTICS

S.No	Characteristics	Results	Lower and Upper permissible limit as per IS10500 2012
01	Appearance	Normal	Normal
02	Colour	Agreeable	Agreeable
03	Turbidity (Units)	Agreeable	Agreeable
04	Odour	No odour	Unobjectionable

B-CHEMICAL CHARACTERISTICS

05	p ^H	6.8	6.5 –8.5
06	Electrical Conductivity(Microhoms/cm at 25°C)	140	
The following values are expressed as mgs/L			
07	Dissolved Solids (105°C)	70	500-
08	Alkalinity/Phenolphalein	0	
09	Methyl Orange (as Ca CO ₃)	22	
10	Total Hardness (as Ca CO ₃)	20	
11	Carbonate Hardness (as Ca CO ₃)	20	
12	Non-Carbonate Hardness (as Ca CO ₃)	0	
13	Chlorides (as Cl)	20	
14	Nitrates (as N)	0	45
15	Flourides (as F)	0.2	0.5-1.5
16	Ammoniacal Nitrogen	Nil	Absent
17	Albuminoidal Nitrogen	Nil	Absent
18	Nitrites (as NO ₂)	Nil	Absent
19	Oxygen consumed from KMnO ₄	ND	
20	Iron	0.1	1.0
21	Sulphates	0	200

C - BACTERIOLOGICAL EXAMINATION

22	Presumptive coliform test (MPN)	N	NIL
23	Confirmative test for E coli sp	N	NEGATIVE
24	Other organism isolated if any		

Remarks:

CHEMICAL QUALITY: SATISFACTORY

BACTERIOLOGICAL QUALITY: SATISFACTORY


10/7/2025
SENIOR WATER ANALYST
DISTRICT PUBLIC HEALTH LABORATORY
6-1-3 A, HOSPITAL ROAD
TIRUPATHI - 517 507